



City of
Parksville

2010 ANNUAL WATER REPORT



June 2011

Engineering and Operations Department

1.0	INTRODUCTION	3
2.0	PARKSVILLE WATER SYSTEM	3
3.0	DISTRIBUTION SYSTEM	6
4.0	SCADA	11
5.0	WATER SAMPLING AND TESTING.....	12
6.0	WATER QUALITY COMPLAINTS	13
7.0	MAINTNENACE PROGRAM	14
8.0	2010 IMPROVEMENTS	15
9.0	2010 CAPITAL PROJECTS	15
10.0	2011 CAPITAL PROJECTS & IMPROVEMENTS.....	15
11.0	CROSS CONNECTION	16
12.0	EMERGENCY RESPONSE PLAN.....	16

APPENDIX A - WELL LOCATION MAP**APPENDIX B - ARROWSMITH DAM LAKE LEVELS 2003-2010****APPENDIX C - MAP OF PRESSURE ZONES****APPENDIX D - 2010 BACTERIOLOGICAL TEST RESULTS****APPENDIX E - FULL SPECTRUM ANALYSIS****1.0 Introduction:**

All water suppliers, under their Operating Permit, are required to provide an annual report to their users with information such as explanation of water source, water test results, maintenance programs and improvements to the water system. The following document summarizes these requirements.

This report has been submitted to the Vancouver Island Health Authority and is posted on the City of Parksville Website. www.Parksville.ca.

2.0 Parksville Water System:

The City of Parksville has approximately 4500 water connections serving over 11,000 permanent and seasonal residents as well as supplying water to the Regional District of Nanaimo - Nanoose Bay Peninsula system in the summer months.

These users get their drinking water from 3 sources.

- Englishman River Intake
- Springwood Well Field
- Railway Well Field

The water is treated using either liquid or gaseous chlorine and stored in 4 reservoirs at either end of the City.



2.1 Groundwater Wells:

The City's groundwater is pumped from a confined quadra sands aquifer that runs underground alongside the railway tracks from Trill Drive to the City's boundary in the southwest. The City currently has 18 production wells ranging from 3.3 l/s (44 IGPM) to 9.0 l/s (118 IGPM). See **Appendix A** for Well locations.

Well Name	Well Depth (m)	Production (l/s, Igpm)
Springwood Well #1	31.9	3.9 , 51
Springwood Well #2	10.4	Off Line
Springwood Well #3	25.3	5.2 , 69
Springwood Well #4	9.8	4.7 , 62
Springwood Well #5	31.0	6.5 , 87
Springwood Well #6	31.1	5.7 , 76
Springwood Well #7	40.2	5.7 , 76
Springwood Well #8	39.4	4.1 , 55
Springwood Well #10	25.6	9.0, 118
Springwood Well #11	30.6	7.0, 92
Railway Well#1	30.7	5.5 , 73
Railway Well#2	32.2	4.9 , 65
Railway Well#3	25.2	3.3 , 44
Railway Well#4	22.5	3.4 , 45
Railway Well#5	36.3	6.9 , 91
Railway Well#6	36.7	5.2 , 69
Railway Well#7	34.2	4.6 , 61
Railway Well #8	28.6	7.0, 92
Trill Well#8	25.1	Off Line

2.2 River Intake:

Between May and October the City pumps water from the Englishman River at a maximum rate of 159 l/s (2100 IGPM) to keep up with summer demands. The water in the Englishman river is partially supplied from the Arrowsmith Dam. The Ministry of Environment, Fisheries and The Arrowsmith Water Service (AWS) developed an operating rule curve in an effort to conserve reservoir storage water for critical fisheries rearing periods. A minimum flow is released into the river based on this curve between June 1st and October 31st. (See Appendix B)

2.3 Arrowsmith Dam:

The City of Parksville, The Regional District of Nanaimo, and The Town of Qualicum are partners in the Arrowsmith Water Service (AWS). The dam is located at Arrowsmith Lake approximately 19km south of Parksville. It was commissioned in September 2000. The dam has a capacity of 9,000,000 m³ and is operated and maintained by City of Parksville staff. Water is released to the Englishman river through 2 pipes, a 900 mm and a 600 mm with flows and lake levels monitored by the City's Supervisory Control and Data Acquisition (SCADA) system.

See **Appendix B** for Arrowsmith Dam Lakes Levels 2003 – 2010.

2.4 Reservoirs:

Water that has been pumped either from the ground or from the river is stored in 5 reservoirs. Reservoirs numbers 1, 2 and 4 are located in the Springwood Water Compound on Despard Rd. These 3 are concrete with 2 being partially below ground and one above. Storage capacities are:

- Reservoir #1 - 616 m³ (135,500 Imp. gal).
- Reservoir #2 - 2023 m³ (445,000 Imp. gal)
- Reservoir #4 - 4559 m³ (1,000,000 Imp. gal).

There are 2 additional reservoirs at the Top Bridge Park area, numbers 3 and 5. Reservoir #5 is a glass fused steel tank, Reservoir #3 is a steel tank although currently not in use. Storage capacities are:

- Reservoir #3 - 671m³ (148,000 Imp. gal.)
- Reservoir #5 - 4300 m³ (950,000 Imp. gal).


3.0 Distribution System:

The distribution system consists of 54 km of PVC (plastic) pipe, 8.3 km of Ductile Iron pipe and 32 km of AC (Asbestos Cement) pipe. Sizes range from 4" to 14".

There are 468 fire hydrants and one Pressure Reducing Valve (PRV).

Like all municipalities, the infrastructure is aging and water mains are being replaced through capital improvements. The following shows the size, age and material of the mains in the Parksville Water System in 2009. 2010 Data has not yet been graphed.


2009 Watermains - Proportions of Diameter



2009 Watermains Proportions of Diameter

Diameter	No Pipes	Distance (km)	Percentage	Type
150mm or less	559	41.960	44.2%	Distribution Mains
200mm	336	22.467	23.6%	67.8%
250mm	166	12.830	13.5%	Supply Mains
300mm	142	11.000	11.6%	32.2%
Greater than 350mm	80	6.757	7.1%	
Total:	1283	95.014	km	


2009 Watermains - Proportions of Age



2009 Watermains Proportions of Age

Age	No Pipes	Distance (km)	Percentage
Under 25 Years (>1983)	696	48.676	51.2%
25 - 50 Years (1958 to 1982)	559	45.862	48.3%
Over 50 Years (<1958 or = 0)	28	0.476	0.5%
Total:	1283	95.014 km	

2009 Watermain Materials Proportions



2009 Watermains Proportions of Materials

Material Types	Distance (km)	Percentage
Asbestos Cement	32.184	33.9%
Ductile Iron	8.318	8.8%
PVC	54.186	57.0%
Steel	0.327	0.3%
Total:	95.014 km	

3.1 Pressure Zones:

The City is divided into 2 pressure zones. A low pressure and a high pressure. The low pressure is a gravity fed system based on the elevation of Reservoir #4 and Reservoir #5. A top water level of 73.74m above sea level (geodetic) gives a range of 55 psi to 85 psi throughout the system, depending on the geographic location.

The high pressure system initially was developed for higher elevation regions of the city that didn't have sufficient pressures or flows to meet fire fighting flows. This high pressure zone has been expanded to areas furthest from the pump stations that lose pressure and flow due to line losses. In order to maintain a balance between high and low pressures but still keep a safe pressure in the lower areas, a PRV was installed to drop the pressure from 80psi to 60psi.


The high pressure water in this zone is supplied from 4 pumps, a 15hp, 2-40hp and a 100 hp. These pumps are controlled through the SCADA system that automatically watches flows and switches on however many pumps it needs to meet the flow requirements.

See **Appendix C** for Map of Pressure Zone Boundaries.



4.0 SCADA (Supervisory Control and Data Acquisition):

The water system and sewer pump stations are controlled by a computerized control system called SCADA. This system allows the Operators to monitor reservoir levels, the on/off status and flows of pumps, and monitor chlorine residuals. The operator can change set points and monitor the system remotely. Alarms are automatically called out to City staff that monitor the system 24 hours a day, 7 days a week.



5.0 Water Sampling and Testing

5.1 Bacteriological

As required by the Vancouver Island Health Authority (VIHA), City staff take weekly bacteriological samples to be tested for Total Coliforms and e-Coli Bacteria. There are 16 dedicated sampling sites throughout the city.

See **Appendix D** for 2010 test results (L1 means Less than 1 - Acceptable)

5.2 Full Spectrum Analysis

In addition to weekly sampling throughout the distribution system, the City also sends samples from the source water once per year, in the Fall, for a full spectrum analysis. As seen in Appendix E, parameters such as metals (iron, manganese) conventional parameters (pH, Turbidity, Hardness) and disinfection byproducts (Trihalomethane) are tested.

The source water is aesthetically acceptable as set by the "Guidelines for Canadian Drinking Water Summary Table". Aesthetic qualities apply to certain substances or characteristics such as high Iron content which will stain fixtures red or Manganese which will stain black.

Hardness in the water comes from calcium carbonate (CaCO_3). The river water is considered "Soft" under the guidelines and the Well water is "Moderate". Hardness levels above 500 mg/l are normally considered unacceptable.

All parameters meet the Canadian Drinking Water Guidelines.

See **Appendix E** for the 2010 Full Spectrum Analysis of the Parksville Water System Source Water.



6.0 Water Quality Complaints

The Engineering and Operations Department had very few water quality complaints throughout 2010. Most were related to a noticeable chlorine taste in the water. A majority of these complaints were from residences closest to the pump station where the chlorine is injected. We have the occasional complaint of residents' tea tasting funny. Chlorine seems to make tea taste a bit different at times.

There were a few hardness related complaints mostly contributed to new homeowners from other municipalities who are used to different water composition.

There were also a few "brown or dirty water" complaints that came from flushing fire hydrants during maintenance or changes in flows with or without the river pump station on line.



7.0 Routine Maintenance Program

7.1 Distribution

- Water mains are flushed using a unidirectional flushing program
- Air relief valves are cleaned
- Fireline meters are cleaned
- Fire Hydrants are completely disassembled and inspected on a 2 year rotation
- Paint and brush out around hydrants as needed
- All irrigation backflow prevention devices tested and repaired if needed

7.2 Wells

- Daily security check of all wells
- Rehabilitation of 1-2 wells per year
- Pumps and motors replaced as necessary
- Filling chlorine tank on Springwood Well #1 as needed
- Annual water sampling

7.3 River Intake

- Winter maintenance of chlorination system while off line
- Weekly blowing of air lines through intake screens
- Daily checks of pump flows and chlorine levels
- Monthly calibration of turbidity analyzers

7.4 Reservoirs

- Daily security check of tanks and compounds
- Yearly cleaning of Reservoir #1 and 2.
- Clean Reservoir #4 and 5 using divers every 5 years.

7.5 Pump Stations

- Daily checks of pumps and chlorination system
- Security checks of compounds
- Bi-Annual calibration of chlorine analyzers and turbidimeters

8.0 2010 Improvements:

- Installed a new 15 HP vertical turbine pump with variable frequency drive motor at Springwood Pump Station
- Purchased a new chlorine analyzer for River Pump Station
- Replaced River Pump Station Pump #2
- Final upgrade of SCADA system to current technologies
- Continue to replace old style flush outs at dead ends to improve flows while flushing
- In consultation with Fisheries and Environment, a contractor was hired to rake the river intake gallery to remove the fine sands plugging up the intake

9.0 2010 Capital Projects:

- Moilliet Street: water, sewer, storm
- Arrowsmith Water Service hired consultants to do an engineering study on feasibility of a water treatment plant for the area

10.0 2011 Capital Projects and Improvements:

- Continue upgrading SCADA data historian
- Continue with well rehabilitation on aging wells
- Starting a water meter change out program
- Continue developing the cross connection program
- Develop a comprehensive water conservation program
- River intake gallery cleaning
- Continuing to replace aging water mains for better distribution.
- As per the Drinking Water Protection Act, the 4321 rule affecting surface water supplies is being addressed through the Arrowsmith Water Service with an engineering study looking at an updated river intake and water treatment plant. Start piloting various treatment processes

11.0 Cross Connection Control Program

In May 2006 the City of Parksville developed a draft cross connection control program as is currently working on the implementation of it.

The cross connection program will be implemented in a manner that will address high and severe hazard water use processes first. These include Industrial, Commercial and Institutional (ICI) users. Each ICI user will be assessed as to the potential risk to the water system. An approved backflow device will have to be installed.

All City owner facilities were assessed and appropriate backflow installed. A tracking program called Backflow Prevention Maintenance Software was installed to track devices around the City and produce letters reminding businesses of when testing is due.

City staff remain watchful of potential cross connections in the fields and report problems back to Cross Connection Control Coordinator.




Double Check Valve Assembly

12.0


Emergency Response Plan

The City of Parksville has an Emergency Response Plan pertaining to the water system available for public viewing at the Engineering and Operations Department. This document outlines the strategies to deal with events such as contamination of water supply, pump failures and turbidity events. This plan continues to be updated.


Well Locations Map



Arrowsmith Dam Lake Levels 2003 - 2010



Map of Pressure Zone Boundaries



2010 Bacteriological Results

Water Sample Range Report

Vancouver Island Health Authority
Central Island

Facility Name: PARKSVILLE, WWS
Facility Type: DWT
Date Range: Jan 1 2010 to Dec 31 2010
Date Created: Jan 21 2011

<u>Sampling Site</u>	<u>Date Collected</u>	<u>Total Coliform</u>	<u>E. Coli</u>	<u>Fecal Coliform</u>
<u>401 S. Molliet Street, Parksville BC, Despard & Molliet, Dist. site, Monthly</u>				
	06/01/2010	L1	L1	
	23/02/2010	L1	L1	
	24/03/2010	L1	L1	
	20/04/2010	1	L1	
	26/05/2010	L1	L1	
	07/07/2010	L1	L1	
	17/08/2010	L1	L1	
	21/09/2010	L1	L1	
	19/10/2010	L1	L1	
	23/11/2010	L1	L1	
	07/12/2010	L1	L1	
Total Positive:	1	0		0
<u>Harbour Homes, Parksville BC, Top of Corfield, Parksville , Dist. site, Monthly</u>				
	12/01/2010	L1	L1	
	03/02/2010	L1	L1	
	16/03/2010	L1	L1	
	20/04/2010	L1	L1	
	19/05/2010	L1	L1	
	09/06/2010	L1	L1	
	13/07/2010	L1	L1	
	04/08/2010	T		
	21/09/2010	L1	L1	
	13/10/2010	L1	L1	
	23/11/2010	L1	L1	
	07/12/2010	L1	L1	
Total Positive:	0	0		0

2010 Bacteriological Results

1247 Arbutus Road,

Parksville BC,

Parksville

MHP/Utility Building,

Parksville, Dist. site,

Monthly

06/01/2010	L1	L1	
09/02/2010	L1	L1	
09/03/2010	L1	L1	
14/04/2010	L1	L1	
04/05/2010	L1	L1	
02/06/2010	L1	L1	
13/07/2010	L1	L1	
04/08/2010	L1	L1	
08/09/2010	L1	L1	
05/10/2010	L1	L1	
03/11/2010	L1	L1	
07/12/2010	L1	L1	
Total Positive:	0	0	0

Craig Bay Heritage

Museum, Parksville

BC, Craig Bay

Heritage Museum,

Parksville, Dist. site,

Monthly

12/01/2010	L1	L1	
23/02/2010	L1	L1	
24/03/2010	L1	L1	
20/04/2010	L1	L1	
19/05/2010	L1	L1	
16/06/2010	L1	L1	
28/07/2010	L1	L1	
10/08/2010	L1	L1	
21/09/2010	L1	L1	
26/10/2010	L1	L1	
16/11/2010	L1	L1	
14/12/2010	L1	L1	
Total Positive:	0	0	0

2010 Bacteriological Results

330 Park View,
Parksville BC, 330

Park View,
Parksville, Dist. site,
Monthly

12/01/2010	L1	L1	
09/02/2010	L1	L1	
03/03/2010	L1	L1	
14/04/2010	L1	L1	
11/05/2010	L1	L1	
02/06/2010	L1	L1	
20/07/2010	L1	L1	
04/08/2010	T		
08/09/2010	L1	L1	
05/10/2010	L1	L1	
30/11/2010	L1	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

1390 Herring Gull
Way, Parksville BC,
Works Yard,
Parksville, Dist. site,
Monthly

26/01/2010	L1	L1	
17/02/2010	L1	L1	
03/03/2010	L1	L1	
07/04/2010	L1	L1	
11/05/2010	L1	L1	
09/06/2010	L1	L1	
20/07/2010	L1	L1	
24/08/2010	L1	L1	
14/09/2010	L1	L1	
13/10/2010	L1	L1	
09/11/2010	L1	L1	
07/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

2010 Bacteriological Results

613 Chinook Avenue, Parksville BC, 613 Chinook Avenue, Parksville
Dist. site, Monthly

19/01/2010	L1	L1	
17/02/2010	L1	L1	
30/03/2010	L1	L1	
14/04/2010	L1	L1	
19/05/2010	L1	L1	
09/06/2010	L1	L1	
13/07/2010	L1	L1	
04/08/2010	L1	L1	
14/09/2010	L1	L1	
13/10/2010	L1	L1	
03/11/2010	L1	L1	
14/12/2010	L1	L1	
Total Positive:	0	0	0

193 East Island Highway, Parksville BC, Community Park, Parksville BC,
Dist. site, Monthly

06/01/2010	L1	L1	
17/02/2010	L1	L1	
09/03/2010	L1	L1	
07/04/2010	L1	L1	
04/05/2010	L1	L1	
16/06/2010	L1	L1	
28/07/2010	L1	L1	
17/08/2010	L1	L1	
14/09/2010	L1	L1	
26/10/2010	L1	L1	
30/11/2010	L1	L1	
07/12/2010	L1	L1	
Total Positive:	0	0	0

2010 Bacteriological Results

Daffodil at Camas,

Parksville BC,

Daffodil at Camas,

Parksville, Dist. site,

Monthly

19/01/2010	L1	L1	
03/02/2010	L1	L1	
03/03/2010	L1	L1	
27/04/2010	L1	L1	
26/05/2010	L1	L1	
02/06/2010	L1	L1	
28/07/2010	74	L1	
04/08/2010	1	Resampled	L1
24/08/2010	L1	L1	
14/09/2010	L1	L1	
26/10/2010	L1	L1	
16/11/2010	L1	L1	
07/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	2		0

271 Chestnut Street,

Parksville BC, 271

Chestnut Street,

Parksville, Dist. site,

Monthly

19/01/2010	L1	L1	
23/02/2010	L1	L1	
09/03/2010	L1	L1	
07/04/2010	L1	L1	
26/05/2010	L1	L1	
23/06/2010	L1	L1	
13/07/2010	L1	L1	
17/08/2010	L1	L1	
21/09/2010	L1	L1	
13/10/2010	L1	L1	
09/11/2010	L1	L1	
07/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0		0

2010 Bacteriological Results

851 Temple, 851
TEMPLE (beside),
Dist. site, Monthly

19/01/2010	L1	L1	
17/02/2010	L1	L1	
03/03/2010	L1	L1	
07/04/2010	L1	L1	
11/05/2010	L1	L1	
16/06/2010	L1	L1	
28/07/2010	L1	L1	
10/08/2010	L1	L1	
08/09/2010	L1	L1	
05/10/2010	L1	L1	
09/11/2010	L1	L1	
07/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

378 Kingsley Street,
Wheeler, Top of
Kingsley, Dist. site,
Monthly

26/01/2010	L1	L1	
09/02/2010	L1	L1	
09/03/2010	L1	L1	
27/04/2010	L1	L1	
04/05/2010	L1	L1	
23/06/2010	L1	L1	
20/07/2010	L1	L1	
10/08/2010	L1	L1	
08/09/2010	L1	L1	
05/10/2010	L1	L1	
03/11/2010	L1	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

Englishman River
Intake, River Pump
Station, Dist. site,
Monthly

26/01/2010	L1	L1	
23/02/2010	L1	L1	
30/03/2010	L1	L1	
27/04/2010	L1	L1	
26/05/2010	L1	L1	
07/07/2010	L1	L1	
31/08/2010	L1	L1	
28/09/2010	L1	L1	
19/10/2010	L1	L1	
23/11/2010	3.0	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	1	0	0

2010 Bacteriological Results

450 Wisteria, across
from 450 Wisteria,
Dist. site, Monthly

06/01/2010	L1	L1	
09/02/2010	L1	L1	
16/03/2010	L1	L1	
14/04/2010	L1	L1	
04/05/2010	L1	L1	
02/06/2010	L1	L1	
20/07/2010	L1	L1	
17/08/2010	L1	L1	
28/09/2010	L1	L1	
19/10/2010	L1	L1	
16/11/2010	L1	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

136 Memorial, Dist.
site, Monthly

26/01/2010	L1	L1	
03/02/2010	L1	L1	
16/03/2010	L1	L1	
27/04/2010	L1	L1	
11/05/2010	L1	L1	
07/07/2010		L1	
31/08/2010	L1	L1	
28/09/2010	L1	L1	
26/10/2010	L1	L1	
30/11/2010	L1	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

Island Highway, by
Temple, Island
Highway, by Temple,
Dist. site, Monthly

12/01/2010	L1	L1	
03/02/2010	L1	L1	
24/03/2010	L1	L1	
20/04/2010	L1	L1	
19/05/2010	L1	L1	
23/06/2010	L1	L1	
07/07/2010	L1	L1	
24/08/2010	L1	L1	
28/09/2010	L1	L1	
19/10/2010	L1	L1	
30/11/2010	L1	L1	
14/12/2010	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

Result Values:

E - estimated

L - less than

G - greater than

2010 Bacteriological Results

Samples that contain total coliform:	4	2.11% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of positive samples in last 30 days:	0/16	
Total number of samples:	190	

Comments:

Environmental Health Officer
Jun 14 2011

FOR FURTHER INFORMATION PLEASE CALL: Wrathall, Bill (250) 947-8222 Parksville

Operator

City of Parksville
1116 Herring Gull Way
Parksville, BC
V9P 2H3

(250) 248-5412

Maxxam Job # B0A1862
 Report Date: 2010/11/05

City of Parksville

Success Through Sc

Your P.O. #: 6573

RESULTS OF CHEMICAL ANALYSES OF WATER

				X85205	X85266	X85267	X85203	X85209	
Maxxam ID				2010/10/20	2010/10/20 09:45	2010/10/20 09:30	2010/10/20	2010/10/20 08:30	
Sampling Date				08:00				08:55	
CONVENTIONALS									
Transmittance at 254nm	%T/cm			89.9					N/A 4376032
ANIONS									
Nitrite (N)	mg/L	1		<0.002	<0.002	<0.002	<0.002	<0.002	0.002 4363246
Calculated Parameters									
Nitrate (N)	mg/L	10		0.027	0.460	0.583	0.937	0.339	0.002 4360565
Misc. Inorganics									
Fluoride (F)	mg/L	1.5		0.02	0.05	0.05	0.04	0.05	0.01 4377868
Alkalinity (Total as CaCO ₃)	mg/L			26	98	92	116	106	2 4360043
Total Organic Carbon (C)	mg/L			1.2	<0.5	0.6	0.8	<0.5	0.5 4370122
Bicarbonate (HCO ₃)	mg/L			32	119	112	136	130	2 4360043
Carbonate (CO ₃)	mg/L			2	2	2	2	2	2 4360043
Hydroxide (OH)	mg/L			2	2	2	2	2	2 4360043
Anions									
Dissolved Sulphate (SO ₄)	mg/L	500	<0.5	2.6	2.3	2.0	2.9	0.5	4370151
Dissolved Chloride (Cl)	mg/L		250	11	16	11	31	23	0.5 4370145
MISCELLANEOUS									
True Colour	Col. Unit		15	8	<5	<5	<5	<5	5 4362344
Tannins and Lignins	mg/L		0.2	<0.1	<0.1	<0.1	<0.1	<0.1	0.1 4362189
Nutrients									
Ammonia (N)	mg/L		<0.005	<0.005	<0.005	0.003	<0.005	0.005	4370353
Total Total Kjeldahl Nitrogen (Calc)	mg/L		0.12	<0.02	0.04	<0.02	0.05	0.02	4368353
Nitrate plus Nitrite (N)	mg/L	10		0.027	0.460	0.583	0.937	0.339	0.002 4366281
Total Nitrogen (N)	mg/L		0.14	0.45	0.62	0.90	0.38	0.02	4368862
Physical Properties									
Conductivity	µS/cm		96	265	239	390	319	1	4360126
pH	pH Units		6.5:8.5	7.0	7.2	7.3	7.2	7.3	4360129
Physical Properties									
Total Dissolved Solids	mg/L		500	69	153	145	204	177	10 4361120
Turbidity	NTU		0.2	0.2	0.4	0.4	0.4	0.4	0.1 4362351

N/A = Not Applicable

RDL = Reportable Detection Limit

Criteria A: CDW/QG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDLs

Criteria 2 A: Aesthetic Objective as set by "Guidelines for Canadian Drinking Water Quality."

Maxxam Job #: B0A1862
Report Date: 2010/11/05

City of Parksville

Your P.O. #: 6573

Successor Tr

MICROBIOLOGY (WATER)

Maxxam ID		X85265	X85266	X85267	X85268	X85269	
Sampling Date		2010/10/20	2010/10/20	09:45	2010/10/20	09:30	2010/10/20
	Units	Criteria A	RIVER P/S	SPRINGWOOD	SPRINGWOOD	RAILWAY	RAILWAY
			WELL #3	WELL #7	WELL #2	WELL #6	WELL #2
Microbiological Param.							
E. coli	MPN/100mL	0	11	<1	<1	<1	1
Total Coliforms	MPN/100mL	0	250	<1	<1	<1	1
							4361110

RDL = Reportable Detection Limit
Criteria A, Criteria B, Criteria C: CDWQG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDLs

Maxxam

Maxxam Job #: B0A1862
Report Date: 2010/11/05

City of Parksville

Your P.O. #: 6573

Succes... Thr...

CSR TOTAL METALS IN WATER (WATER)

Maxxam ID					X85265	X85266	X85267	
Sampling Date					2010/10/20	2010/10/20	09:45	2010/10/20 09:30
	Units	Criteria A	Criteria B	Criteria C	RIVER P/S	SPRINGWOOD	SPRINGWOOD	RDL QC Batch
Calculated Parameters								
Total Hardness (CaCO ₃)	mg/L	5	20	100	37.3	122	126	0.5 4357857
Total Metals by ICPMS								
Total Aluminum (Al)	ug/L	6			35	4	9	3 4389236
Total Arsenic (As)	ug/L	10			<0.5	<0.5	<0.5	0.5 4389236
Total Barium (Ba)	ug/L	1000			7	6	4	1 4389236
Total Bismuth (Bi)	ug/L				<0.1	<0.1	<0.1	0.1 4389236
Total Boron (B)	ug/L	5000			<1	<1	<1	1 4389236
Total Cadmium (Cd)	ug/L	5			<0	<0	<50	50 4389236
Total Chromium (Cr)	ug/L	50			<0.01	<0.01	0.02	0.01 4389236
Total Cobalt (Co)	ug/L				2	<1	1	1 4389236
Total Copper (Cu)	ug/L				<0.5	<0.5	<0.5	0.5 4389236
Total Iron (Fe)	ug/L	10			1000	33.1	0.6	0.2 4389236
Total Lead (Pb)	ug/L				300	59	34	24 5 4389236
Total Lithium (Li)	ug/L				0.2	0.2	0.4	0.2 4389236
Total Manganese (Mn)	ug/L				<5	<5	<5	5 4389236
Total Mercury (Hg)	ug/L	1			50	2	56	15 1 4389236
Total Molybdenum (Mo)	ug/L				<0.02	<0.02	<0.02	0.02 4389236
Total Nickel (Ni)	ug/L				<1	<1	<1	1 4389236
Total Selenium (Se)	ug/L	10			<0.1	0.1	<0.1	0.1 4389236
Total Silicon (Si)	ug/L				3330	12900	13900	100 4389236
Total Silver (Ag)	ug/L				<0.02	<0.02	<0.02	0.02 4389236
Total Strontium (Sr)	ug/L				50	69	63	1 4389236
Total Thallium (Tl)	ug/L				<0.05	<0.05	<0.05	0.05 4389236
Total Tin (Sn)	ug/L				<5	<5	<5	5 4389236
Total Titanium (Ti)	ug/L				<5	<5	<5	5 4389236
Total Uranium (U)	ug/L	20			<0.1	0.1	<0.1	0.1 4389236
Total Vanadium (V)	ug/L				<5	<5	6	5 4389236
Total Zinc (Zn)	ug/L				5000	13	5	4389236
Total Zirconium (Zr)	ug/L				<0.5	<0.5	<0.5	0.5 4389236
Total Calcium (Ca)	mg/L				12.0	26.1	25.3	0.05 4357858

RDL = Reportable Detection Limit

Criteria A, Criteria B, Criteria C: CDWQG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDLs

Criteria 2 A: Aesthetic Objective as set by "Guidelines for Canadian Drinking Water Quality."

Maxxam Job #: B0A1862

Report Date: 2010/11/05

City of Parksville

Your P.O. #: 6573

Success Thru

MICROBIOLOGY (WATER)

Maxxam ID		X85265	X85266	X85267	X85268	X85269		
Sampling Date		2010/10/20 08:00	2010/10/20 09:45	2010/10/20 09:30	2010/10/20 08:30	2010/10/20 08:55		
	Units	Criteria A	RIVER P/S	SPRINGWOOD	SPRINGWOOD	RAILWAY	RAILWAY	RDL
Microbiological Param.								QC Batch
E. coli	MPN/100mL	0	11	<1	<1	<1	<1	1
Total Coliforms	MPN/100mL	0	250	<1	<1	<1	<1	1

RDL = Reportable Detection Limit
 Criteria A, Criteria B, Criteria C: CDWQG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDLs

Maxxam Job #: B0A1862
Report Date: 2010/10/05

City of Parksville

Your P.O. #: 6573

Success Thr.

CSR TOTAL METALS IN WATER (WATER)

Maxxam ID				X85268		X85269	
Sampling Date				2010/10/20 08:30		2010/10/20 08:55	
	Units	Criteria A	Criteria B	Criteria C	Criteria 2 A	RAILWAY	RDL QC Batch
Calculated Parameters							
Total Hardness (CaCO ₃)	mg/L	5	20	100	166	4357857	121
Total Metals by ICPMS							
Total Aluminum (Al)	ug/L	6			4	4389236	8
Total Antimony (Sb)	ug/L	10			<0.5	4389236	<0.5
Total Arsenic (As)	ug/L	1000			0.2	4389236	0.5
Total Barium (Ba)	ug/L				15	4389236	1
Total Beryllium (Be)	ug/L				<0.1	4389236	0.1
Total Bismuth (Bi)	ug/L				<1	4389236	1
Total Boron (B)	ug/L	5000			<50	4389236	50
Total Cadmium (Cd)	ug/L	5			<0.01	4389236	0.01
Total Chromium (Cr)	ug/L	50			<1	4389236	1
Total Cobalt (Co)	ug/L				<0.5	4389236	0.5
Total Copper (Cu)	ug/L				1000	4389236	1.0
Total Iron (Fe)	ug/L				300	4389236	25
Total Lead (Pb)	ug/L	10			<0.2	4389236	0.2
Total Lithium (Li)	ug/L				<5	4389236	5
Total Manganese (Mn)	ug/L				50	4389236	6
Total Mercury (Hg)	ug/L	1			<0.02	4389236	<0.02
Total Molybdenum (Mo)	ug/L				<1	4389236	1
Total Nickel (Ni)	ug/L				<1	4389236	1
Total Selenium (Se)	ug/L	10			<0.1	4389236	0.1
Total Silicon (Si)	ug/L				11900	4389236	10100
Total Silver (Ag)	ug/L				<0.02	4389236	<0.02
Total Strontium (Sr)	ug/L				103	4389236	1
Total Thallium (Tl)	ug/L				<0.05	4389236	0.05
Total Tin (Sn)	ug/L				<5	4389236	5
Total Titanium (Ti)	ug/L				<5	4389236	5
Total Uranium (U)	ug/L	20			0.2	4389236	0.1
Total Vanadium (V)	ug/L				<5	4389236	5
Total Zinc (Zn)	ug/L	5000			11	4389236	5
Total Zirconium (Zr)	ug/L				<0.5	4389236	0.5
Total Calcium (Ca)	mg/L				35.1	4357858	27.4

RDL = Reportable Detection Limit

Criteria A, Criteria B, Criteria C: CDWQG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDL's
Criteria 2 A: Aesthetic Objective as set by "Guidelines for Canadian Drinking Water Quality."

Maxxam Job #: B0A1862
Report Date: 2010/11/05

City of Parksville

Your P.O. #: 6573

Success Three

CSR TOTAL METALS IN WATER (WATER)

Maxxam ID					X85268	X85269		
Sampling Date					2010/10/20 08:30	2010/10/20 08:55	RDL	QC Batch
	Units	Criteria A	Criteria B	Criteria C	Criteria 2 A	RAILWAY WELL #2	RAILWAY WELL #6	QC Batch
Total Magnesium (Mg)	mg/L				19.1	4357858	12.7	0.05
Total Potassium (K)	mg/L				0.86	4357858	0.71	0.05
Total Sodium (Na)	mg/L				200	4357858	7.22	0.05
Total Sulphur (S)	mg/L				<3	4357858	<3	3

RDL = Reportable Detection Limit
Criteria A, Criteria B, Criteria C: CDWQG Potability (Health Criteria at Point of Use / Distribution) - for Victoria requirement for <1 micro RDLs
Criteria 2 A: Aesthetic Objective as set by "Guidelines for Canadian Drinking Water Quality."